



CERTIFICATE OF COMPLIANCE

FOR

IIMAK Manufacturing Services
Reynosa, Tamaulipas

Gowning Room

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 8 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments.

This clean zone was tested in the At Rest occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared September 2009.

Date of Certification: September 22, 2009

Due for Retest: September-2010

Certified By: John Koester

Reviewed: CENV200909187/Jeff McCabe



CERTIFICATE OF COMPLIANCE

FOR

IIMAK Manufacturing Services
Reynosa, Tamaulipas

Cleanroom

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 8 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments.

This clean zone was tested in the At Rest occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared September 2009.

Date of Certification: September 22, 2009

Due for Retest: September-2010

Certified By: John Koester

Reviewed: CENV200909187/Jeff McCabe